

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No: 7167-1126:118 Page 1 of 1

CATEGORY: Control Units (Non High-Rise)

LISTEE: Interactive Technology Inc, 2266 Second St North, North Saint Paul, MN 55109
Contact: *Randy Libersky (651) 773-2235

DESIGN: Models "Concord" 60-734 and 60-792-95R combination household fire and burglary fire alarm control units. Refer to listee's data sheet for detailed product description and operational considerations. System components:

| | |
|--------------------|-----------------------------------|
| 60-734 | Hardwire Control Unit |
| 60-792-95R | RF Control Unit |
| 60-728 | LED Touchpad |
| 60-746 | Touchpad |
| 60-764-95R | SAW Receiver |
| 60-756, -757, -758 | Snap Card |
| 60-777 | Phone Interface Module with Voice |

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical rating and UL label.

APPROVAL: Listed as combination household fire and burglary alarm control units for use with separately listed compatible initiating and indicating devices.

This control unit can generate a distinctive three-pulse Temporal Pattern Fire Alarm Evacuation Signal (for total evacuation) in accordance with NFPA 72, 1993 Edition. Refer to manufacturer's Installation Manual for details.

NOTE:

1. Burglary and other non-fire functions were not examined. Refer to listee's data sheet or installation instructions for compatible non-fire devices.
2. **Fire Alarm Verification Feature** is NOT approved for use in California. This feature shall not be programmed into the system.

*Rev. 06-12-2002



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued:

JUNE 12, 2002

*Listing Expires **June 30, 2003***

Authorized By:

DIANE K. AREND, Senior Deputy
Program Manager